



Product Technical Data Sheet:
TDSCCFS

PFC Corofil Cavity Fire Stop CCFS

(Table on page 7 headed 'CCFS Plain tested to EN1366-4' is not included in the classification)

Classified to EN13501-2
3rd Party Certification IFCC1667
UL-EU-01231-CPR



**CAVITY
BARRIERS**



Technical Description of Product



PFC Corofil Cavity Fire Stop full fill cavity barrier is a stone wool product installed between the façade and the inner structure of a building to reinstate the fire resistance performance of the cavity.

PFC Corofil Cavity Fire Stop has been tested to EN1366-4 and EN1363-1 TR031 and will provide up to 120 minutes fire integrity and insulation performance.

PFC Corofil Cavity Fire Stop is cut to size to suit the cavity width and can be supplied as plain stone wool, foil encapsulated, or with an integral DPC.

Intended Use

PFC Corofil Cavity Fire Stop has been designed and tested to be installed within building cavities between the façade and the inner structure. It can be installed against SFS with a calcium silicate fibre cement board and masonry substrates in both horizontal and vertical orientations. PFC Corofil Cavity Fire Stop can be installed in a masonry support system* in cavities up to 450mm wide. PFC Corofil Cavity Fire Stop is suitable for cavity widths up to 600mm.

This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in and is suitable for your application (see PFC Corofil terms and conditions 13.1.1).

* Please see substrates on page 5 for the masonry support system specification

Key Points

- Suitable for cavities up to 600mm (please see tables from page 5).
- Can be installed against SFS with a calcium silicate fibre cement board.
- Can be installed against aerated concrete, concrete and masonry substrates.
- Can be installed in a masonry support system (please see substrates on page 5 for specification).
- Provides up to 120 minutes fire integrity and insulation performance (please see tables from page 5).

Installation Instructions



Cavity widths up to 200mm wide (minimum thickness of CCFS 100mm)

- Ensure surfaces are clean, dry and free from dirt, dust, mortar and other contaminants.
- Ensure the opening to be filled has been tested with and is suitable for the product being installed.
- Cut back any insulation fixed to the inner substrate prior to installation of the PFC Corofil Cavity Fire Stop.
- The PFC Corofil Cavity Fire Stop should be installed with a minimum 5mm compression.
- Any cutting of the PFC Corofil Cavity Fire Stop on site to suit tolerances, shall be done accurately and kept to a minimum. Ensure that the minimum 5mm extra for the compression is maintained.
- Compress the PFC Corofil Cavity Fire Stop and push into the cavity.
- When extending the length of the PFC Corofil Cavity Fire Stop, ensure the adjacent lengths have their joints tightly abutted together and are aligned flush with each other to give the appearance of a continuous strip with no gaps.
- Fill any gaps up to 5mm wide with PFC Corofil Acoustic Intumescent Sealant to a minimum depth of 10mm.

Cavity widths 201mm to 600mm wide (minimum thickness of CCFS 82mm)

- Ensure surfaces are clean, dry and free from dirt, dust, mortar and other contaminants.
- Ensure the opening to be filled has been tested with and is suitable for the product being installed.
- Cut back any insulation fixed to the inner substrate prior to installation of the PFC Corofil Cavity Fire Stop.
- The PFC Corofil Cavity Fire Stop should be installed with a minimum 5mm compression.
- Any cutting of the PFC Corofil Cavity Fire Stop on site to suit tolerances, shall be done accurately and kept to a minimum. Ensure that the minimum 5mm extra for the compression is maintained.
- For masonry applications, fix PFC Corofil Multipurpose Brackets to the substrate using 1 no. non-combustible steel screw minimum 4mm x 40mm long (supplied by others) and position the leg of the brackets to the midpoint of the PFC Corofil Cavity Fire Stop. The brackets should be fixed 250mm from each end of each individual section of barrier at maximum 500mm centres.
- For calcium silicate fibre cement board applications, fix PFC Corofil Multipurpose Brackets to the substrate using 1 no. 6mm x 32mm coarse threaded steel screw suitable for the board (supplied by others) and position the leg of the brackets to the midpoint of the PFC Corofil Cavity Fire Stop. The brackets should be fixed 250mm from each end of each individual section of barrier at maximum 500mm centres.
- When fixing the brackets to any other substrate, please contact a fixing supplier for advice on the correct fixings.
- When cutting lengths to fit at the end of a run, install one bracket centrally in lengths up to 300mm, for lengths 301mm to 500mm 2 brackets should still be used distanced equally from each end.
- Push the PFC Corofil Cavity Fire Stop onto the leg of the bracket so it is spiked into the centre along the length and compress into the cavity. There should be at least 25mm between the end of the bracket and the outer face of the barrier.
- Fill any gaps up to 5mm with PFC Corofil Acoustic Intumescent Sealant to a minimum depth of 10mm.

Installation Instructions



Masonry Support System (minimum thickness of CCFS 82mm)

- Ensure surfaces are clean, dry and free from dirt, dust, mortar and other contaminants.
- Ensure the opening to be filled has been tested with and is suitable for the product being installed.
- Cut back any insulation fixed to the inner substrate prior to installation of the CCFS.
- The CCFS should be installed with a minimum 5mm compression.
- Any cutting of the CCFS on site to suit tolerances, shall be done accurately and kept to a minimum. Ensure that the minimum 5mm extra for the compression is maintained.
- Ensure there is a minimum of 28mm from the top of the masonry support bracket to the top of the floor slab.
- Mark where the brackets meet the CCFS and cut a notch into the CCFS.
- Compress the PFC Corofil Cavity Fire Stop and push into the cavity, ensuring the top of the CCFS sits flush with the top surface of the floor slab.
- When extending the length of the CCFS, ensure the adjacent lengths have their joints tightly abutted together and are aligned flush with each other to give the appearance of a continuous strip with no gaps.
- Fill any gaps up to 5mm with PFC Corofil Acoustic Intumescent Sealant to a minimum depth of 10mm. of 10mm.

Installation Instructions



Substrates

- Rigid walls: Minimum 100mm thick and comprise of concrete, aerated concrete or masonry, with a minimum density of 650kg/m³.
 - Rigid Floors: Minimum 150mm thick and comprise of concrete, aerated concrete or masonry, with a minimum density of 650kg/m³.
 - SFS system: 135mm overall thickness comprising, 90mm Metsec C stud clad internally with 2 x 15mm Knauf Fire Panel, clad externally with 1 x 12mm RCM Y-Wall panel and 75mm Rockwool Duo slab.
 - Masonry support system: Ancon Masonry Support System MDC/P to suit a 450mm cavity.
-

Terminology

Fire resistance classes:

E = Integrity. The length of time it takes for the fire to pass to the non-fire side.

I = Insulation. The length of time it takes for the heat of the fire to pass to the non-fire side.

Performance Data



Rigid Floors minimum thickness 150mm

PFC Corofil Cavity Fire Stop installed against Rigid Floors minimum 150mm thick				
Overall Cavity width (mm)	Minimum thickness of Cavity Fire Stop (mm)	Orientation	Brackets required	Fire resistance performance
10 - 100 with or without integral DPC	100	Horizontal	No	EI120
101 - 200 with or without integral DPC	100		No	E120 EI90
201 - 450 with or without integral DPC	82		Yes	E120 EI30
451 - 595 with or without integral DPC			Yes	E60 EI30

Rigid Walls minimum thickness 100mm

PFC Corofil Cavity Fire Stop installed against Rigid walls minimum 100mm thick.				
Overall Cavity width (mm)	Minimum thickness of Cavity Fire Stop (mm)	Orientation	Brackets required	Fire resistance performance
10 - 200 with or without integral DPC	100	Vertical	No	EI120
201 - 600 with or without integral DPC	82		Yes	E120 EI30

SFS system with calcium silicate cement fibre board

PFC Corofil Cavity Fire Stop installed against SFS system (see substrates on page 5 for full specification) to masonry outer substrate.				
Overall Cavity width (mm)	Minimum thickness of Cavity Fire Stop (mm)	Orientation	Brackets required	Fire resistance performance
10 - 595	82	Horizontal	Yes	E120 EI60
10 - 600	82	Vertical	Yes	E120 EI30

Performance Data



Rigid Floors minimum thickness 150mm with masonry support system

PFC Corofil Cavity Fire Stop installed horizontally against an Ancon MDC/P Masonry Support System fixed to a rigid floor slab minimum 150mm thick				
Overall Cavity width (mm)	Minimum thickness of Cavity Fire Stop (mm)	Minimum gap from top of Masonry support bracket to top of floor slab (mm)	Brackets required	Fire resistance performance
10 - 200 with or without integral DPC	82	28	No	EI120
201 - 450 with or without integral DPC			Yes	E120 EI30

‘CCFS Plain, Tested to EN1366-4’

PFC Corofil Firestop installed (CCFS) Plain installed in a masonry substrate Rigid walls minimum thickness 100mm Rigid floors minimum thickness 150mm					
Overall Cavity Width (mm)	Minimum thickness of Cavity Fire Stop (mm)	Orientation	Brackets required	Fire resistance performance	
				Integrity (minutes)	Insulation (minutes)
201 - 300	100	Horizontal	Yes	120	120
		Vertical			

Please note: The products and fire resistance performances listed in this table are not included in the classification



Doc Reference	TDSCCFS	
Revision 1.7		
PB: DQ	CB: CI	AB: SE
This Copy	Review Date	
21/12/2023	13/01/2026	



King Georges Trading Estate | Davis Road | Chessington | KT9 1TT
T. +44 (0) 208 391 0533
E. sales@pfc-corofil.com | tech@pfc-corofil.com | W. pfc-corofil.com

This data sheet shows the only applications the product has been tested in. Please ensure the product has been tested in and is suitable for your application (see PFC Corofil terms and conditions 13.1.1). Downloaded and printed data sheets are uncontrolled. For latest copy please check www.pfc-corofil.com